



TÜRK STANDARDLARI ENSTİTÜSÜ
TÜRK STANDARDLARINA UYGUNLUK BELGESİ
TURKISH STANDARDS INSTITUTION
CERTIFICATE OF CONFORMITY TO TURKISH STANDARDS

Markanın Tanımı Description of the Mark
TSE veya/or  veya/or T S E

BELGE NUMARASI REFERENCE NUMBER OF LICENCE	109513-TSE-02/07
BELGENİN İLK VERİLİŞ TARİHİ DATE OF FIRST ISSUE OF LICENCE	10.05.2013
BELGENİN SON GEÇERLİLİK TARİHİ LICENCE VALID UNTIL	23.10.2025
BELGE SAHİBİ KURULUŞUN ADI NAME OF THE LICENCE HOLDER	AKSA POWER GENERATION (CHINA) CO., LTD.
BELGE SAHİBİ KURULUŞUN ADRESİ ADDRESS OF THE LICENCE HOLDER	NO:19 TONGJIANG NORTH ROAD, CHANGZHOU NEW DISTRICT, CHANGZHOU, CHINA -/ÇİN
ÜRETİM YERİ ADI NAME OF THE MANUFACTURING PLACE	AKSA POWER GENERATION (CHINA) CO., LTD.
ÜRETİM YERİ ADRESİ ADDRESS OF THE MANUFACTURING PLACE	NO:19 TONGJIANG NORTH ROAD, CHANGZHOU NEW DISTRICT, CHANGZHOU, CHINA - / ÇİN
İPTAL EDİLEN BELGE NUMARASI (Varsa) INDICATION OF SUPERSEDED LICENCE (if any)	109513-TSE-02/06
TESCİLLİ TİCARİ MARKASI REGISTERED TRADE MARK	AKSA
İLGİLİ TÜRK STANDARDI RELATED TURKISH STANDARD	TS ISO 8528-5 / 30.09.2022 -- TS EN ISO 8528-13 / 13.04.2018
BELGE KAPSAMI SCOPE OF LICENCE	

GENERATOR GROUPS (DIESEL)

-APDXXXA Model, AKSA Engine, Prime 10.6 KVA/ 8.5 kW (included), Standby from 11.5 KVA/ 9.2 kW (Prime 10.6 KVA - Standby 11.5 KVA included), Prime 410 KVA, 328 kW Standby up to 450 KVA/ 360 kW (Prime 410 kVA - Standby 450 kVA included) 230/400V, 50Hz, G3 Performance class IP21M WITHOUT CABINET-IP 23M WITH CABINET, 3 phase Automatic or Manual operation control unit Generator groups, Diesel Fuel

-APDXXXA Model, CROWN KRAFT Engine, from Prime 11 KVA/ 8.8 kW (included), Standby 12 KVA/ 9.6 kW (Prime 11 KVA - Standby 12 KVA included), up to prime 410 KVA, 328 kW standby 451 KVA/ 360.8 kW (Prime 410 kVA – Standby 451 kVA included) 230/400V, 50Hz, G3 Performance class IP21M WITHOUT CABINET-IP 23M WITH CABINET, 3 phase Automatic or Manual start control unit Generator groups, Diesel Fuel

-APDXXXM Model, MITSUBISHI Engine, from Prime 600 KVA/480kW - Standby 660 KVA/528kW (Prime 600 KVA -

e-imzalı/e-signed

03.12.2024

On Behalf Of The Head Of Certification Center
SOYDAN CERAN

ELECTROTECHNICAL SECTOR MANAGER

*This certificate also shows that the production place of the certified product meets the requirements of Institute.

*This certificate under any circumstances cannot be changed, duplicated partially or in a way that makes it difficult to read and erasure cannot be done.

*TSE ELECTROTECHNIC SECTOR DIRECTORATE * Address: Necatibey Cad.No:112 06100 Bakanlıklar/ANKARA * Telephone: 0312 416 63 96* Fax: 0312-416 66 17

*TSE HEAD OF CERTIFICATION CENTER; Address: Necatibey Cad. No:112 06100 Bakanlıklar/ANKARA – Telephone: 0 312 416 64 81 / 416 64 27, Fax:0 312 416 66 17 E-mail :bmb@tse.org.tr , web : www.tse.org.tr





TÜRK STANDARDLARI ENSTİTÜSÜ
TÜRK STANDARDLARINA UYGUNLUK BELGESİ
TURKISH STANDARDS INSTITUTION
CERTIFICATE OF CONFORMITY TO TURKISH STANDARDS



(109513-TSE-02/07nolu belge devamı) : AKSA POWER GENERATION (CHINA) CO., LTD.
İLGİLİ TÜRK STANDARDI(RELATED TURKISH STANDARD) TS ISO 8528-5 / 30.09.2022 -- TS EN ISO 8528-13 / 13.04.2018

Standby 660 KVA included) up to Prime 2500 KVA/2000kW - Standby 2750 KVA/2200kW (Prime 2500 KVA - Standby 2750 KVA included) 230/400V, 50Hz, G3 Performance Class, IP21M WITHOUT CABINET - IP23M WITH CABINET ,Three Phase Automatic or Manual Start Control Unit Generator Sets,Diesel Fuel

-ADXXX Model, Doosan Engine, from Prime 84KVA/67.2kW - Standby 93 KVA/74.4kW (Prime 84 KVA - Standby 93KVA included) up to Prime 750KVA/600kW- Standby 825 KVA/660 kW (Prime 750KVA - Standby 825 KVA included) 230/400V,50Hz,G3 Performance Class, IP21M WITHOUT CABINET –IP23M CABINET, Three Phase Automatic or Manual Start Control Unit, Diesel Generator Sets

-ADXXX Model, HYUNDAI Engine, from Prime 84KVA/67.2kW - Standby 93 KVA/74.4kW (Prime 84 KVA – Standby 93KVA included) up to Prime 915 KVA, 732 kW, - Standby 1015 KVA, 812 kW (Prime 915KVA - Standby 1015 KVA included) 230/400V, 50Hz, G3 Performance Class, IP21M WITHOUT CABINET – IP23M WITH CABINET, Three Phase Automatic or Manual Start Control Unit, Diesel Generator Groups (K.D 25.11.2024)

APDXXXXBD model, BAUDOUIN Engine, from Prime 18 KVA/14.4 kW- Standby 20 kVA/16 kW (Prime 18 kVA, Standby 20 kVA included), up to Prime 2050 KVA 1640 kW, Standby 2250 KVA, 1800 kW (Prime 2050 kVA-Standby Up to 2250 kVA), 230/400V, 50Hz, G3 Performance Class, IP21M WITHOUT CABINET – IP23M WITH CABINET, Three Phase Automatic or Manual Operation Control Unit, Diesel Generator Groups (K.D 25.11.2024)

-APDXXXXC Model, CUMMINS Engine, from Prime 20 KVA, 16 kW, Standby 22 KVA, 17.6 kW, (Prime 20 KVA - Standby 22 KVA included), 230/400V, up to Prime 2750 KVA/2200kW – Standby 3000 KVA/2400 kW, (Prime 2700 kVA – Standby 3 000 kVA included), 230/400V, 50Hz, G3 Performance Class, IP21M WITHOUT CABINET-IP 23M WITH CABINET, 3 phase Automatic or Manual operation control unit Generator groups, Diesel Fuel (K.D 25.11.2024)

Alternators tested at maximum power together with generator groups;
Stamford brand Alternator maximum power Prime 2790 KVA / 2232 kW , Standby 3069 KVA / 2455kW up
Meccalte brand Alternator maximum power Prime 750KVA / 600 kW , Standby , up to 825 KVA / 660 kW
Aksa brand Alternator maximum power Prime 450 KVA / 360 kW Standby 495 KVA / 396 kW up
Leroy Somer brand Alternator maximum power Prime 2700 KVA / 2160 kW , Standby 2970 KVA / 2276 kW up
(K.D 11.09.2019)
AKSA brand Alternator maximum power Prime 600kVA / 480 kW, Standby 660kVA / 528kW
(K.D 10.01.2023)

e-imzalı/e-signed

03.12.2024

On Behalf Of The Head Of Certification Center
SOYDAN CERAN

ELECTROTECHNICAL SECTOR MANAGER

*This certificate also shows that the production place of the certified product meets the requirements of Institute.

*This certificate under any circumstances cannot be changed, duplicated partially or in a way that makes it difficult to read and erasure cannot be done.

*TSE ELECTROTECHNIC SECTOR DIRECTORATE * Address: Necatibey Cad.No:112 06100 Bakanlıklar/ANKARA * Telephone: 0312 416 63 96* Fax: 0312-416 66 17

*TSE HEAD OF CERTIFICATION CENTER; Address: Necatibey Cad. No:112 06100 Bakanlıklar/ANKARA – Telephone: 0 312 416 64 81 / 416 64 27, Fax:0 312 416 66 17 E-mail :bmb@tse.org.tr , web : www.tse.org.tr

