



TÜRK STANDARDLARI ENSTİTÜSÜ
TÜRK STANDARDLARINA UYGUNLUK BELGESİ
TURKISH STANDARDS INSTITUTION
CERTIFICATE OF CONFORMITY TO TURKISH STANDARDS

Markanın Tanımı Description of the Mark
TSE veya/or  veya/or T S E

BELGE NUMARASI REFERENCE NUMBER OF LICENCE	109513-TSE-02/06
BELGENİN İLK VERİLİŞ TARİHİ DATE OF FIRST ISSUE OF LICENCE	10.05.2013
BELGENİN SON GEÇERLİLİK TARİHİ LICENCE VALID UNTIL	23.10.2025
BELGE SAHİBİ KURULUŞUN ADI NAME OF THE LICENCE HOLDER	AKSA POWER GENERATION (CHINA) CO., LTD.
BELGE SAHİBİ KURULUŞUN ADRESİ ADDRESS OF THE LICENCE HOLDER	NO:19 TONGJIANG NORTH ROAD, CHANGZHOU NEW DISTRICT, CHANGZHOU, CHINA -/ÇİN
ÜRETİM YERİ ADI NAME OF THE MANUFACTURING PLACE	AKSA POWER GENERATION (CHINA) CO., LTD.
ÜRETİM YERİ ADRESİ ADDRESS OF THE MANUFACTURING PLACE	NO:19 TONGJIANG NORTH ROAD, CHANGZHOU NEW DISTRICT, CHANGZHOU, CHINA - / ÇİN
İPTAL EDİLEN BELGE NUMARASI (Varsa) INDICATION OF SUPERSEDED LICENCE (if any)	109513-TSE-02/05
TESCİLLİ TİCARİ MARKASI REGISTERED TRADE MARK	aksa
İLGİLİ TÜRK STANDARDI RELATED TURKISH STANDARD	TS ISO 8528-4 / 27.08.2015
BELGE KAPSAMI SCOPE OF LICENCE	

* CONTROL DEVICE AND CONNECTION HARDWARE (CONTROL PANEL)
-SP 20 Model,
- RATED WORKING VOLTAGE:12-24 V DC,230/400 V AC,
RATED INSULATION VOLTAGE:690 V, ENVIRONMENT DECLARATION CONDITIONS -25 C/+40 C, RATED
FREQUENCY:50/60 Hz,IP 41
PROTECTION CLASS,IK 10,INTERNAL TYPE

* CONTROL DEVICE AND CONNECTION HARDWARE (CONTROL PANEL)
-SP 20 Model,
- RATED WORKING VOLTAGE:12-24 V DC,230/400 V AC,
RATED INSULATION VOLTAGE:690 V, ENVIRONMENT DECLARATION CONDITIONS -25 C/+40 C, RATED
FREQUENCY: 50/60 Hz, IP 43
PROTECTION CLASS, IK 10, INTERNAL TYPE (21.10.2024 K.D)

e-imzalı/e-signed

03.12.2024

On Behalf Of The Head Of Certification Center
SOYDAN CERAN

ELECTROTECHNICAL SECTOR MANAGER

*This certificate also shows that the production place of the certified product meets the requirements of Institute.

*This certificate under any circumstances cannot be changed, duplicated partially or in a way that makes it difficult to read and erasure cannot be done.

*TSE ELECTROTECHNIC SECTOR DIRECTORATE * Address: Necatibey Cad.No:112 06100 Bakanlıklar/ANKARA * Telephone: 0312 416 63 96* Fax: 0312-416 66 17

*TSE HEAD OF CERTIFICATION CENTER; Address: Necatibey Cad. No:112 06100 Bakanlıklar/ANKARA – Telephone: 0 312 416 64 81 / 416 64 27, Fax:0 312 416 66 17 E-mail :bmb@tse.org.tr , web : www.tse.org.tr





TÜRK STANDARDLARI ENSTİTÜSÜ
TÜRK STANDARDLARINA UYGUNLUK BELGESİ
TURKISH STANDARDS INSTITUTION
CERTIFICATE OF CONFORMITY TO TURKISH STANDARDS

Markanın Tanımı Description of the Mark
TSE veya/or  veya/or **T S E**

(109513-TSE-02/06nolu belge devamı) : AKSA POWER GENERATION (CHINA) CO., LTD.
İLGİLİ TÜRK STANDARDI (RELATED TURKISH STANDARD) TS ISO 8528-4 / 27.08.2015

e-imzalı/e-signed

03.12.2024

On Behalf Of The Head Of Certification Center
SOYDAN CERAN

ELECTROTECHNICAL SECTOR MANAGER

*This certificate also shows that the production place of the certified product meets the requirements of Institute.

*This certificate under any circumstances cannot be changed, duplicated partially or in a way that makes it difficult to read and erasure cannot be done.

*TSE ELECTROTECHNIC SECTOR DIRECTORATE * Address: Necatibey Cad.No:112 06100 Bakanlıklar/ANKARA * Telephone: 0312 416 63 96* Fax: 0312-416 66 17

*TSE HEAD OF CERTIFICATION CENTER; Address: Necatibey Cad. No:112 06100 Bakanlıklar/ANKARA – Telephone: 0 312 416 64 81 / 416 64 27, Fax:0 312 416 66 17 E-mail :bmb@tse.org.tr , web : www.tse.org.tr

